

Valuing Capacity for Resources with Energy Limitations – Preliminary Independent Assessment


Kevin Carden

1-25-2019

Overview


- **Astrapé was hired by NY-BEST to perform energy limited capacity valuation analysis**
- **Astrapé presented framework and load analysis on 12/18.**
- **Presentation agenda:**
 - Review SERVM framework
 - Review preliminary results and drivers
 - Next steps

Astrapé Resource Adequacy Clients




SERVM Framework


- **Capture Uncertainty in the Following Variables**
 - Weather (38 years of weather history)
 - Impact on Load and Resources (hydro, wind, PV, temp derates on thermal resources)
 - Economic Load Forecast Error (distribution of 5 points)
 - Unit Outage Modeling (100s of iterations)
- **Multi-Area Modeling – Pipe and Bubble Representation**
- **Total Base Case Scenario Breakdown**



Incorporating Weather Uncertainty for Load




Peak Load Variability by Weather Year




Effect of Load Scaling for Uncertainty

IRM Loads Compared to Historical Load Shapes





Frequency of Days with >4 Hours Above Load Threshold



Load Forecast Uncertainty and Forward Period


- Non-weather load forecast error increases with forward period
- Each weather shape simulated with each LFE and associated probabilities



Unit Outage Modeling


- **Full Outages**
 - Time to Repair
 - Time to Failure
- **Partial Outages**
 - Time to Repair
 - Time to Failure
 - Derate Percentage
- **Startup Failures**
- **Maintenance Outages**
- **Planned Outages**
- **Created Based on Historical GADS Data**

- Multi State Frequency and Duration Modeling vs Convolution



Multi-Area Modeling

- Pipe and Bubble Representation with import and export constraints
- Constraints can be constants, distributions, tied to load level, or input by month
- Ties can be modeled with random outages
- Areas will share resources based on economic pricing and physical constraints
- Load/Wind/Hydro diversity is embedded in each region's input data



Energy Limited Duration Approach


■ Study Steps

- Model all loads and resources in NYCA, ISO-NE, PJM, IESO, HQ
 - Include existing PSH with constraints in NYCA
 - Include energy limited resources (DR and PSH) in neighboring regions
- Calibrate reliability in NYCA and neighboring regions to 0.1 LOLE
- Add energy limited capacity
- Remove perfect (no duration limit and no forced outage rate) conventional capacity until NYCA reliability again meets 0.1 LOLE
- Fractional capacity value = Perfect capacity removed / energy limited capacity added

Key Assumptions


- **Simulated at criterion for NYCA and neighbors**
- **Reserves fully exhausted before shedding firm load**
- **Capacity value instead of ELCC**
- **Energy limited resources compared to perfect capacity**
- **Endogenous simulations**
- **2019 resource mix**
- **Existing pumped storage hydro always modeled with 8-hour duration**
- **Magnitude of each portfolio directly comparable to GE portfolios, although composition is different due to PSH treatment.**

Preliminary 4 Hour Duration Results




**All energy limited resource portfolios include 1408 MW of 8-hour PSH.*

Preliminary 4 Hour Diversity Benefit



**All energy limited resource portfolios include 1408 MW of 8-hour PSH.*

Preliminary 2 & 6 Hour Duration Results



**All energy limited resource portfolios include 1408 MW of 8-hour PSH.*

Drivers of Differences from GE Study

- **Treatment of load uncertainty**
- **Diversity with neighbors; GE MARS study assumes no diversity**
- **Endogenous treatment of resource interactions**
- **Generator outage modeling**
- **Internal transmission constraints**

Regional Load Diversity


- **Regional load diversity is not realistic in the GE simulations**
 - Artificial correlation in 3 highest load days
- **Diversity results in higher shoulder period purchase availability, shortening the need for duration**

	Peak Load	Load Diversity	
	(MW)	(% below non-coincident 50/50 peak)	
	Non-Coincident Peak Load	At System Coincident Peak	At NYISO Coincident Peak
NYISO	36,427	-5.9%	0.0%
PJM	163,597	-0.9%	-3.8%
ISONE	26,762	-7.9%	-3.3%
IESO	24,404	-9.1%	-14.2%
System	291,297	0.0%	-2.3%

Imports by Load Level

- Higher purchase availability at sub-peak hours shortens duration need

SERVM Modeled Net Imports as a Function of NYCA Coincident Load



Preliminary IRM Calibration

- **Each zone set to 50/50 2019 forecast**
- **Conventional generation moved within zones and internal constraints relaxed to achieve reliability parity across NYISO**
- **Conventional generation removed (CC/CT) until LOLE = 0.1**
- **Resulting IRM = 13.7%**
 - NYSRC 'No internal NYCA transmission constraints' sensitivity demonstrates 2.4% lower IRM = **14.4% RM**
 - SERVM likely sees more import benefit due to load diversity
- **Additional calibration to be performed**

Next Steps


- **Simulate additional duration, penetration, and resource mix scenarios.**
- **Simulate with IRM load profiles in SERVVM with must-run dispatch**
- **2-3 weeks for additional simulations and documentation**

Appendix

EFOR vs EFORD

	NYCA
SERVM EFOR	12.9%
SERVM EFORD	7.2%

FOHd = Hours forced out AND unit would have been operated



$$FOR = \frac{FOH}{FOH + SH}$$

$$FOR = \frac{12}{12 + 100} = 10.7\%$$

$$FORd = \frac{FOHd}{FOHd + SH}$$

$$FORd = \frac{6}{6 + 100} = 5.6\%$$