



# 2023 Integrated Resource Plan (IRP)

## Public Stakeholder Meeting #3

June 28, 2022

# Santee Cooper Resource Adequacy Studies

Astrapé Consulting

# Topics of Discussion

- **Planning Reserve Margin (PRM) Study Results**
- **ELCC Study Results**
- **Solar Integration Study Update**

## Planning Reserve Margin (PRM) Study Results


# SERVM Framework

- **Capture Uncertainty in the Following Variables**

- Weather: 41 years of weather history (1980-2020) with equal probability of occurrence
  - Impact on Load and Resources (hydro, wind, PV, temp derates on thermal resources)
- Economic Load Forecast Error: Distribution of 5 points with varying probabilities of occurrence
- Unit Outage Modeling (25+ iterations for each load scenario)

- **Multi-Area Modeling – Pipe and Bubble Representation**

- **Total Base Case Scenario Breakdown**




# Major Study Parameters


- **Study Years: 2026 & 2029**
- **Historical Weather Years: 1980-2020**
- **Regions (Balancing Authority Areas) Modeled**
  - Santee Cooper
  - Southern Company (SOCO)
  - Duke Energy Carolinas (DEC)
  - Duke Energy Progress (DEP)
  - Dominion Energy South Carolina (DESC)
  - Target 0.1 LOLE for neighboring regions
- Maintain minimum regulating reserves of 100 MW during firm load shed events
- **Target LOLE:** 0.1 Days/Year = 1 firm load shed event in 10 years

# Minimum Annual Temperatures Since 1930

**Weighted SC Historical Minimum Temps  
(57% Columbia/43% Charleston)**




# Historical Minimum Temperatures – Percent of Years







# Daily Max/Min Temperatures vs Daily Max Load




# Summer Peak Load Variability



# Winter Peak Load Variability



# Economic Load Forecast Uncertainty




Derived from Congressional Budget Office GDP forecast error over last 30 years. GDP Load forecast error multiplied by 40% to reflect electric load growing less than GDP.

LFE	Probability
-4%	10.4%
-2%	23.3%
0%	32.5%
2%	23.3%
4%	10.4%


# Generator Outage Data

- **NERC Generating Availability Data System (GADS) is Confidential**
  - EFORs based on 5 years of historical GADS data captured as annual outage rates
  - EFORs subject to adjustments made by SC Management on forward looking expectations
  - Planned maintenance rates based on future planning
    - Optimized by SERVIM based on net load over the 41 weather years
- Astrape analyzed recent cold weather events in the GADS data and thermal generation performed well so no incremental cold weather outages were modeled for Santee Cooper


# Winter Base Case Results



# LOLE by Month



# LOLE By Weather Year





# Sensitivities

## 1. Island Case

- Assumes no market exists around the Santee Cooper system

## 2. Climate Change Sensitivity

- Adjust temperatures 0.3°/Decade per NOAA Climate Change Study


## 3. 2 Load Sensitivities

- LOW: Cap Winter Loads at highest value in historical data
- HIGH: Adjust load response until winter volatility reaches 30% (similar to recent ERCOT experience)

## 4. Transmission Sensitivity

- Constraint the combined DESC/SC import to 1,500 MW

# Load Sensitivity Inputs



# Summary of Sensitivity Results

	Winter	2026	2029
Base Case Market		17.8%	18.3%
Base Case Island		27.1%	27.7%
Climate Change		16.8%	17.2%
High Load Response		22.0%	22.9%
Low Load Response		14.2%	15.2%
Transmission Import		17.8%	18.5%

# Summer Reserve Margin

- Base case shows almost all LOLE is in the winter (0.0904 Winter / 0.0004 Summer)
  - Neighboring utilities are all long in summer, providing substantial market support
  - This is likely real-world reality
- Allowing LOLE in the summer months to rise to the 0.01-0.02 range would establish a reasonable summer PRM without significantly raising annual LOLE
- Resulting summer PRM would be in the 14%-16% range

# Recommendation

- Study supports a winter reserve margin of 17%-18%
  - Recommendation:
    - Adopt a 17% winter reserve margin
    - Target to achieve by 2026
- Study supports a summer reserve margin of 14%-16%
  - Recommendation:
    - Maintain a 15% summer reserve margin

## ELCC Results for Solar and Storage

# Seasonal ELCC Methodology Details

- Start with System at approximately 0.1 LOLE with no renewable resources
  - Record Winter LOLE (Jan, Feb, Dec) as Winter target
  - Record Summer LOLE (Jun-Sep) as Summer target
- Add renewable tranche to system
- For each season, iteratively add load until that season's LOLE returns to target
- ELCC is the load added divided by the nameplate of the renewable tranche

# ELCC Portfolio Matrix to be Evaluated

Solar MW ->	BESS MW				
	0	1,000	1,250	1,500	2,000
	200			200\1,500	
	400				400\2,000

Capturing solar and battery together will ensure any synergistic value of the two resources is considered



## Raw Capacity Value (MW) Winter

BESS\Solar	0	1000	1250	1500	2000
0		20	23	27	28
200	200			279	
400	352				405

## Raw Capacity Value (MW) Summer

BESS\Solar	0	1000	1250	1500	2000
0		393	458	490	537
200	200			708	
400	379				972

## Portfolio ELCC Winter

BESS\Solar	0	1000	1250	1500	2000
0		2.0%	1.8%	1.8%	1.4%
200	100.0%			16.4%	
400	88.0%				16.9%

## Portfolio ELCC Summer

BESS\Solar	0	1000	1250	1500	2000
0		39.3%	36.6%	32.7%	26.9%
200	100.0%			41.6%	
400	94.8%				40.5%

## Allocated Portfolio ELCC Winter

BESS\Solar	0	1000	1250	1500	2000
0		2.0%	1.8%	1.8%	1.4%
200	100.0%			100.0%/5.3%	
400	88.0%				93.8%/1.5%

## Allocated Portfolio ELCC Summer

BESS\Solar	0	1000	1250	1500	2000
0		39.3%	36.6%	32.7%	26.9%
200	100.0%			100.0%/33.9%	
400	94.8%				100.0%/28.5%

# ELCC Additional Thoughts

- Ensure resources are on equal playing field with new thermal generation for capacity expansion decisions
  - New Gas EFOR less than 5%
  - Storage/Solar EFORs are more uncertain
- Santee Cooper and Astrape are discussing ways to ensure storage and solar ELCCs are treated fairly to account for EFORs on new thermal resources
- Cold weather correlated outages were not seen in outage history which demonstrates plants are winterized

# Solar Integration Study Update

# Schedule

- **Finalized thermal resource inputs - Mid June**
- **Started Simulations in late June**
- **Expect Draft Results in July/August**

# Scope of Study

## ■ Solar Tranches Evaluated

	Santee Cooper Solar
Tranche 1 MW	500
Tranche 2 MW	1,000
Tranche 3 MW	1,500
Tranche 4 MW	2,000

## ■ Scenarios Evaluated

- Base Scenario: 2x1 CC
- Alternative Scenario 1: 1x1 CC with 2 Oil CTs
- Alternative Scenario 2: 1x1 CC with 1 Oil CT and 150MW of BESS

# Study Procedure

- **Step 1: Run Base Case:**

- Establish a non-renewables base case at 0.1 LOLE
- Simulate with reasonable operating reserves to determine flexibility violations without solar (e.g. no solar case produced 3 flexibility events per year)

- **Step 2: Add Solar:**

- Return system to 0.1 LOLE
- As solar is added flexibility violations increase due to the increase in net load volatility
- Determine the hours where flexibility violations occur


- **Step 3: Add operating reserves:**

- Add additional operating reserves in the form of load following to get back to the number of flexibility violations in the base case
- Target hours where flexibility violations occur
- By using a set violation target, the model is allowed to make use of periods where reserves are already high due to unit commitment and peak and off peak loads


- **Step 4: Calculate the solar integration cost:**

- Calculate the cost increase of the operating reserves between Step 2 and Step 3. Then divide by the incremental solar generation to calculate the solar integration cost

# Load Intra-Hour Volatility – Included in all simulations




# Solar Volatility as a Function of Penetration




- **Relying on historical solar data**
  - Compare volatility across a range of solar penetration levels
  - See significant diversity benefit from solar tranches
  - Hourly profiles are the same as the reserve margin study




# Solar Intra-Hour Volatility – 500MW Tranche



# Solar Intra-Hour Volatility – 1000MW Tranche



# Solar Intra-Hour Volatility – 1500MW Tranche



# Solar Intra-Hour Volatility – 2000MW Tranche

